

# The Energy Consortium

20 June 2025

Halve the Half?

#### Built Environment – Issues as Opportunities





#### **OUT OF HOURS ENERGY**

**+/- 50%** of Energy consumption is when buildings are empty



#### SUSTAINABILITY AND NEW BUILDINGS

It takes between

#### 156-220 years

For new high-performing structures to emit less CO2 than retrofitting buildings. The design life of new structures is typically 50 years before first major maintenance.

(Abbey, et al., 2022) (EN 1990-2002)



#### **INEFFICIENT SPACE UTILISATION**

Average HE Teaching Space Utilisation =

22.9%

The sector expanded by

 $852,000 \text{ m}^2$  in three years

(AUDE EMR 2022, 2023 & 2024)



### STRIKING PERFORMANCE DISCREPANCY

The actual performance of buildings exceeds design stage projections by

1-4 times

(Shi, et al., 2019))



#### **FUTURE BUILDING LANDSCAPE**

80%

of the buildings we'll see in 2050 are already standing today

(UKGBC 2023)



## HEALTH & PRODUCTIVITY IN VENTILATED BUILDINGS

Properly ventilated spaces boost cognitive function by

**26-51%** 


(MacNaughton, et al., 2017 & Allen, et al., 2015)

#### Net Zero By Sequestration?





 $Welsh\ CO_2\ Emissions\ vs\ Sequestration,\ and\ proportion\ of\ Welsh\ Woodland\ (Welsh\ Government,\ 2021)\ and\ (ADAS,\ 2020)$ 






# Building Performance Gap & Out of Hours Energy

Immediate opportunities to reduce cost and carbon

#### Built Environment, Energy and Carbon




#### International Energy Agency




#### Out of Hours – prior year





Llandaff.Main Electric (kWh) 13/05/2023 - 12/05/2024




Llandaff.Main Gas (kWh) 13/05/2023 - 12/05/2024

#### Out of Hours – last 12 months



Holiday kWh





Weekday Band kWh 81%

Booked Out-of-Hour

Weekend Out-of-Band . kWh

11%

Weekend

Band

kWh\_


0%

Weekday Out-of-Band kWh


#### Out of Hours – comparing the years



Llandaff Electricity 13/5/2024-12/5/25 vs same period prior year





Llandaff Gas 13/5/2024-12/5/25 vs same period prior year



#### **Out of Hours Compared**







■ Llandaff.Main Electric (kWh) 13/05/2023 - 12/05/2024

■ Llandaff.Main Electric (kWh) 12/05/2024 - 12/05/2025

#### Llandaff Gas 13/5/2024-12/5/25 vs same period prior year




■ Llandaff.Main Gas (kWh) 13/05/2023 - 12/05/2024

■ Llandaff.Main Gas (kWh) 12/05/2024 - 12/05/2025

#### Benchmarking: kWh/m2 of GIA (by Segment)






### Net Zero Performance Gap – The Evidence







## Net Zero Performance Gap – The Evidence





<sup>\*</sup> Includes both tariff and consumption reduction

#### The Journey: From Space to Sector-wide Revelations



-20.77 %

Gas Consumption (9 Months)

-8.12 %

Electrical Consumption (10 Months exc EV)

-9.4 %

Water Consumption (10 Months)

-2.03 GWh

Energy Reduction vs period last year

-7,138 m3

Water Consumption

Energy savings delivered within existing maintenance budgets

No Capital.

No grid upgrades.

No planning permission.

Informed by existing half hourly data

-£721k

10 Months accounting for tariff changes

#### Energy Reduction – Investing in Maintenance



Equipment left "In Hand" Maint'
contractors
coming back
and putting
things back
"In Hand"!

Primary
and
Secondary
circuits

Time Clock settings

Link to occupancy

running when they shouldn't be...

Things

Security as eyes and ears Inventory lists – is it being maintained !

Just turn stuff off...

Replacing Filters – and making sure they are done...

Control & Faulty sensors

Billing errors


Backing the engineers

Target out of hours – no one minds!

#### Where to focus?



#### Typical Energy Use TM 46 Office, Air Conditioned



#### Performance Gap – Our Energy Revelation



Buildings don't need energy, people do.

55.3 %

University Electrical use outside M-F 7-7

TEC: 70% UK Universities

1650 Fiscal Meters

56.1 %

University Gas use outside M-F 7-7

60 %

Schools Out-of-Hours Energy

Energy Sparks | Inspired Efficiency | Barkers: 1700 Schools £764M

Annual savings in Education if we half the half

25% of DFE Budget 2024/25 +

25% of Energy Spend based on Hesa spend 22/23




#### CIBSE TM46 – Education EUI is not an outlier




HE

Schools

Other





#### Scaling Beyond Institutions: Built Environment Impact



80 % Buildings in 2050 already exist

**UKGBC** 

27%

Global Energy Emissions from building operations

International Energy Agency

20%

Global Energy Emissions from construction 1-4 x

Performance Gap

Actual vs Design Energy use.

Study of Studies - Shi et al.

#### Transforming the Built Environment?



Cardiff Metropolitan University's initiative suggests that systemic optimisation of existing buildings could offer rapid, scalable cost and carbon reduction, without major investment.

**Immediate** 

Impact timeline

Replicable

Across the built environment

Scalable

You already have the data














## **Internal Environment:**


A Healthy & Productive Environment?




















# Rethinking MEP: Replacement design criteria

#### Replacement plant – how big?




## Example Building Gas Load for different Occupancy Periods





#### Challenging the standards...







Air Handling and Chillers:

Sized to achieve design parameters based on

- 100% occupancy
- on the maximum external temperature
- at the beginning and duration of the day.

#### Heating plant:

Sized to achieve design parameters based on

- 0% occupancy
- On the lowest external temperature
- From a cold start
- For the beginning and duration of the day

#### Challenge the standards...





Requires client-led conversations about design parameters and dispensation from standards:

Potential to reduce plant and distribution sizing

Releasing floor area otherwise used for enlarged plant and distribution

Reducing peak loads – reducing grid impact, capital cost and reserved capacity cost

Plant efficiency curves – Sizing for efficient typical use vs peak of peak capacity


Client/end-users to agree plan for potential response lag/tolerance during temperature extremes



# Grid & Macro Potential

#### Net Zero – Upstream Grid Savings






#### Education Sectors relative to Government Portfolio



Floor area (Million m2 GIA ) Government Estate Portfolios relative to HE GIA (Hesa)




HE + Schools are equivalent to 67+ % Government Portfolio (160 M m²)

HE and Schools are equivalent to 18+ % Nondomestic UK Real Estate (594 M m²)



# Putting it together





No/Low cost Quick Wins

Higher investment Increased Complexity, Longer lead-in and pay-back

#### **Lessons Learnt**



Do you understand your energy consumption out of hours?

Replace perceptions with facts.

Business cases should evidence usage and environment <u>before</u> appointing design teams

Use of IoT occupancy sensors addresses challenges to manual occupancy counts

Monitoring the internal environment in conjunction with occupancy reduces territorial barriers if aligned to resultant priority-based investment decisions

Linking environmental quality to cognitive function, carbon and energy cost creates a compelling case for a taking a different approach

Addressing out of hours energy use is a win-win for cost, carbon and building momentum towards net zero.

**Piloting drives Progress** 



# Rethinking the grid upgrade challenge

## Ynni Cymru Funded Solar PV









Our six-fold increase this year...

2.3 MWp in 294 kWp future?

45kWp

#### Rethinking the grid upgrade to get us to Net Zero



Reveal the Waste

Reduce Waste

**Energy Self Generation** 


Energy Storage

Electrify Heat

What grid upgrade?

#### Efficiency, self-generation, electrification of gas and...






#### Cardiff Metropolitan University Prifysgol Metropolitan **Caerdydd** Efficiency, self-generation, electrification of gas and... 6 GWh 6.1 GWh 2.4 GWh Existing 4.5 GWh Existing Electrical Electrical Demand Demand 21.5 GWh Electrification available Solar 25% Half of Gas Generation the Half if Reserved +3.7 GWh potential capacities drawn 24/7 -1.5 GWh -2.1 GWh

## Llandaff example –heat electrification average (Stc)






# Llandaff Elec and Gas peak loads in last 5 years electrified (stc)




1,550




#### Llandaff Reserved Capacity may be sufficient if energy is stored...





Total day's consumption on day with peak load = 21.5 MWh




6.83 MWh Storage to manage the peak

#### Headroom = Commercial opportunity for Arbitrage

Elec - Tuesday

Elec - Wednesday





Reserved Electrical Capacity (Llandaff)

Latest APX Price (£/MWh)

--- Elec - Friday

- Flec - Saturday

Example intraday block pricing

Intraday energy pricing varies significantly in hourly blocks

Battery storage provides an opportunity to buy low sell high when we don't need the power

Potential opportunities to procure commercial partners under various scenarios for commercial gain or energy price protection.



# Collaboration

#### **Building Level Benchmarks**



A	В	C	G	H	1	J	K	L	M	N	0	P	Q	R	S	T	U	V	V	×	Y	Z	AA	
Organisation name	Confidential	Address	Building Usage (eg office / store /dist)	Gross Internal Floor Area m2	Number of Floors	EPC	reference/identi	Utility type (Elec/gas/water /oil/district heat)	Unit (k₩h or m3)	Opening Time of building	Closing Time of Building	Days of operation	Bank Holidays	ng	Heating Type	₩ater Heating Type		Onsite Generati on (kWh)	Onsite Generation Type	Bed spaces (if applicable)	dedicated	highly- serviced	Contains freezers - commercial catering or ultra- low temperature	Othe
Essential	Assumes No	Essential	Essential	Essential	Desirable	Desirab	Essential	Essential	Essential	Essential	Essential	Essential	Essential	Desirable	Desirable	Desirable	Desirabl	Desirable	Desirable	Desirable	Desirable	Desirable	Desirable	Desir
Notes	YIN		Where combined uses, list uses with 2 floor area for each				Must be unique identifier that matches half hourly export data in Consumption Tab			24hr format (eg 0900)	24hr format (eg 0900)	Mon-Fri, 6 days, 7 days or state custom opening arrangements	Open on Bank Holidays (Y/N)	None / Part (%)/Fully Air conditione d								Labs which require more than one air- change an hour 24/7	Commercial catering or ultra- low temperature	
Example Building		Address					920,000		202000	0.23720	5225			Fully air	20 0 0	20 0 0	Gas	Gas	200					100
1		(Minimum info -	Office	21098	- 2	d	35921	Gas	kwh	08:00	20:0		N:	conditioned	Gas heating	Gas heating	heating	heating	Gasheating					Gash
Example Building 1		Address (Minimum info -	Office	21098	2	d	35922	Electricity	kWh	08:00	20:0		N N	Fully air conditioned	Gas heating	Gasheating	Gas heating	Gas heating	Gas heating					Gash
Example Building		Address (Minimum info -	Office	21098		d	35923	Water	m3	08:00	20:0		N	Fully air conditioned	Gasheating	Gasheating	Gas heating	Gas heating	Gasheating					Gask

	A	В		С		D		
1	RoundedTimeStamp *	Units consumed	*	Units	٧	Meter reference /identifica		
2	01/06/2024 00:00		2	(kWh)		35921		
3	01/06/2024 00:30	1.	5	(kWh)		359	21	
4	01/06/2024 01:00	1.2	(kWh)		359	21		
5	01/06/2024 01:30		4	(kWh)		359	21	
6	01/06/2024 00:00		9	(kWh)		359	22	
7	01/06/2024 00:30		9	(kWh)		359	22	
8	01/06/2024 01:00	1	2	(kWh)		359	22	
9	01/06/2024 01:30	1	2	(kWh)		359	22	
10	01/06/2024 00:00	0.	2	(m3)		359	23	
11	01/06/2024 00:30	0.	5	(kWh)		359	23	
12	01/06/2024 01:00	0.	4	(kWh)		359	23	
13	01/06/2024 01:30	0.	5	(kWh)		359	23	











#### Building Benchmarks – What would be informative?



Organisation name

Confidential

Address

Postcode

**UPRN** 

**Primary Sector** 

Building Usage (eg office / store /dist)

Gross Internal Floor Area m2

**Number of Floors** 

**EPC** 

Meter reference/identifier

Utility type (Elec/gas/water/oil/district heat)

Unit (kWh or m3)

Opening Time of building

Closing Time of Building

Days of operation

**Bank Holidays** 

Air Conditioning

Space Heating Type

Water Heating Type

**Onsite Generation Type** 

Onsite Generation (kWh)

**Onsite Generation Type** 

Bed spaces (if applicable)

Contains dedicated server room(s)

Contains highly-serviced lab(s)

Contains freezers - commercial catering or ultra-low

temperature

Other comments









